

approved
5/19/2020

TOWN OF CARVER, BOARD OF HEALTH

Meeting Minutes BOH April 21, 2020

Public Hearings:

65 Crystal Lake Drive

Board voted to approve subject to applicant securing a temporary easement from abutter at 67 Plymouth St. due to the proposed installation of the chambers being so close to the property line; copy of the document regarding the shared well: execute a 2 bedroom deed restriction; engineer to explain how chambers will be installed (plan shows chambers going "through" the bulkhead).

7 Bates Pond Road

Board voted to approve subject to the plan being stamped by a P.L.S. or provide a Registry of Deed plan reference: show a tee on inlet pipe to the d-box.

3 Everett Street

Board voted to approve subject to asking Webby Eng. if the SAS can be moved to provide more separation to the well.

Discussion:

Covid 19 update

Kevin Forgue provided update stating that all proper procedures are in place: most of the Town Hall staff has had hours reduced and/or furloughed.

EEE update

Kevin Forgue stated that Plymouth County Mosquito Control is scheduled to conduct this year's initial spraying of large wetland areas, this week and will begin private resident spraying the week after Memorial Day.

NCLF private well water sampling

Sample collection of private water wells was extended to include Hines Ave. and Captain Perkins Dr. A total of 16 homes were tested and 3 show a detection of 1.4 diorane. Kevin Forgue has provided bottled water to the 3 homes and is setting up for Poland Springs to deliver a cooler and water to the homes and will be supplied, as such, until the water main is extended.

Update on engineering design for water main extension

Prime Engineering has been contracted to prepare engineering plan for the new water main. Field survey has begun.

Next Meeting date: May 19, 2020 Time: TBA