



TOWN OF CARVER

Permitting Departments

PUBLIC MEETING NOTICE

POSTED IN ACCORDANCE WITH THE PROVISIONS OF M.G.L. CHAPTER 30A, SECTION 20B

BOARD OF HEALTH MEETING AGENDA

April 9, 2019

5:00 PM

Carver Town Hall Room #3

Public Hearing:

1. On the application of Daniel Wood requesting the following variances associated with a septic system upgrade at 4 Crystal Lake Drive, Carver, MA on a 10,000 sq. ft. lot, pursuant to 310 CMR 15.405 local upgrade approval.

310 CMR 15.405 (1)(g)

To allow the installation of a soil absorption system 52 feet from the well on the subject property, instead of 100 feet.

To allow the installation of a soil absorption system 82 feet from the well on the northerly abutting property, instead of 100 feet.

To allow the installation of a soil absorption system 91 feet from the well on the southerly abutting property, instead of 100 feet.

310 CMR 15.405 (1)(b)

To allow the installation of a soil absorption system 13 feet from a cellar wall, instead of 20 feet.

Discussion:

1. Implementation of donation bin regulations, how and when.
2. 66 Main St.-Possible expansion of new restaurant. Capacity of existing system.
3. Upgrade tank replacement requirement.

Other Business

- A. Approve minutes from March 12, 2019
- B. Correspondence (if any)
- C. Set next meeting date
- D. Adjournment