



# **TOWN OF CARVER**

## **Permitting Departments**

### **PUBLIC MEETING NOTICE**

POSTED IN ACCORDANCE WITH THE PROVISIONS OF M.G.L. CHAPTER 30A, SECTION 20B

### **BOARD OF HEALTH MEETING AGENDA**

**October 24, 2017**

**5:00 PM**

**Carver Town Hall Room #3**

#### **Public Hearings:**

On the application of Dorothy Freeman requesting 2 variances under 15.405 (1) (g) and 15.405 (1) (i) located at 15 Pine City Rd. in Carver, Ma. to allow an upgraded septic system on a 13,362 S. F. lot.

#### **Requested Variances:**

1. Installation of a soil absorption system 90' from a well on the property, instead of 100 ft.
2. To allow a sieve analysis in lieu of a percolation test.

#### **Discussion:**

No new items for discussion

#### **Other Business**

- A. Approve minutes of September 26, 2017
- B. Correspondence (if any)
- C. Set next meeting date
- D. Adjournment

